

Date: 2 May 2017

Client: Shield Security Doors Ltd.

Product: Shield Fortress Series (Premium)

Door Type: Inswing

Dimensions (W x H): 1,080 mm x 2,410 mm

Test Method: 15-minute FE testing IAW Section 3.3 of Forced Entry and Ballistic Resistance of Structural Systems, SD-STD-01.01 Revision G (Amended).

Test Results: Sample passed the 15-minute Forced Entry Concentrated Assault test on the Right Edge, and Lower Left Edge Locations. It did not allow passage of 12.0" x 12.0" x 8.0" rigid rectangle or 12.0" x 12.0" rigid cylinder during the 15-minute FE tests on the Right Edge, and Lower Left Edge locations.



Pre Test Photo - Shield Fortress Series (Premium) - Inswing Model

This report shall not be used to claim product certification, approval or endorsement. The results of the testing relate only to the samples submitted for testing and are not representative of a complete model or lot. This test report shall not be interpreted as an endorsement by NTS – Chesapeake Testing as to the continued quality or performance of any items of the same or similar design.

NTS - Chesapeake Testing is an independent testing facility and has no affiliation with Shield Security Doors.