

Evidence of Performance

Burglar Resistance

Test Report 212 37325 e

Translation of Test Report 212 37325 dated
23 March 2009



Client **UAB "Plieninis skydas"**
Kirtimu str. 57A

02244 Vilnius
Lithuania

Basis

DIN V ENV 1627 : 1999
Windows, doors, shutters -
Burglar resistance - Require-
ments and classification
DIN V ENV 1628 : 1999
DIN V ENV 1629 : 1999
DIN V ENV 1630 : 1999

Product	Double leaf burglar resistant doorset
Designation	SKYDAS-PREMIUM (DOUBLE)
Overall dimensions (W x H)	1,500 mm x 2,200 mm
(Frame) Material, system	Steel and wood based panels
Attack side	Closing side/closing face as per DIN 107 and Opening side/opening face as per DIN 107
Type of opening	Double-leaf
Glazing	None
Hardware	Lock Mottura 527 83 D 093 B, hinges 1150 RR/A DX from company Pettiti, Italy
Installation	According to installation instructions as of 2008 from company UAB "Plieninis skydas"
Special features	-/-

Representation



Instructions for use

This test report serves to dem-
onstrate burglar resistance.

Validity

The data and results given refer
solely to the described and
tested specimen. Testing to
burglar resistance does not al-
low any statement to be made
on further characteristics of the
present structure regarding per-
formance and quality.

In deviation from the test type,
the following dimensional
changes are permitted:
width +10% and -20%
height +10% and -20%

Burglar resistance



Resistance Class 4

Notes on publication

The **ift** Guidance Sheet "Condi-
tions and Guidance for the Use
of **ift** Test Documents" applies.
The cover sheet can be used
as abstract.

Contents

The report comprises a total of
51 pages.

- 1 Object
 - 2 Procedure
 - 3 Detailed results
 - 4 Evaluation
- Annex 1 (33 pages)
Annex 2 (2 page)

ift Rosenheim
23 March 2009

Christian Kehrer, Dipl.-Ing. (FH)
Expert
ift Centre of Technical Experts

Konrad Querengässer, Dipl.-Ing. (FH)
Test engineer
ift Centre Doors, gates, Safety and Security



® PTE Rosenheim GmbH
ift Zentrum - Türen Tore Sicherheit
Geschäftsführer:
Dr. Jochen Peichl

Theodor-Gietl-Str. 7 - 9
D-83026 Rosenheim
Tel.: +49 (0)8031/261-0
Fax: +49 (0)8031/261-290
www.pte-rosenheim.de

Sitz: 83026 Rosenheim
AG Traunstein, HRB 14822
Sparkasse Rosenheim
Kto. 500 435 805
BLZ 711 500 00

Notified Body Nr: 0757
Anerkannte PUZ-Stelle: BAY 18

