INSTITUTE OF ARCHITECTURE AND CONSTRUCTION OF KAUNAS UNIVERSITY OF TECHNOLOGY

LABORATORY OF BUILDING PHYSICS

Notified Body number: 2018



TEST REPORT No. 113 SF/19 IS en

Date: 12 of Augustl 2019

page (pages)

1(7)

BURGLAR RESISTANCE

Test methods:

(test name)

LST EN 1628:2011+A1:2016 Pedestrian doorsets, windows, curtain walling, grilles and shutters –

Burglar resistance - Test method for the determination of resistance under static loading.

LST EN 1630:2011+A1:2016 Pedestrian doorsets, windows, curtain walling, grilles and shutters - Burglar resistance - test method for the determination of resistance to manual burglary attempts

(number of normative document or test method, description of test procedure, test uncertainty)

Specimen description:

Customer:

Doors Gerlock Max. Dimensions: Height - 2040mm, width - 1000mm. Material of the frame profile: metal. System: one-handed doors. Opening: rightward inside, rightward outside. Fittings: 1150R/3739. Fixations and places (units) of fixation: 2. Gaskets: the "P" and First and Claring an

"E"shaped. Glazing: none. Other details: none

(identification of the specimen)
UAB "Munitus", Žarijų g. 4, LT-02300 Vilnius

(name and address of enterprise)

Manufacturer: UAB "Munitus", Žarijų g. 4, LT-02300 Vilnius

(name and address of enterprise)

Test results according to LST EN 1627:2011

Name of the indicator and unit	Test standard reference no.	Test result
The resistance under static loading, class	LST EN 1628:2011+A1:2016	RC4- YES
The resistance to manual burglary attempts, class	LST EN 1630:2011+A1:2016	RC4- YES
Note. The testing are carried out in purpose for conformity as	sessment of the product according to LST EN 1	4351-1:2006+A2:2016

Specimen delivery date: 2019-08-05 Test date: 2019-08-06

Sampling: The test specimen sampled by customer. Order description N° 113/19, 2019-08-06

Additions information: Application, 2019-05-21, drawing.

(any deviations, complementary tests, exceptions and any information related with particular test)

Annex:

1 - Cross section of the specimen; 2-Test photo

(the numbers of the annexes should be pointed out)

Technical manager: (approves the test results)

Tested by

(technically responsible for testing)

J. Ramanauskas (n., surname)

V. Paukštys

(n., surname)

surname)

(signature)

(signatur

Validity – the named data and results refer exclusively to the tested and described specimens.

Notes on publication – no part of this document may be photocopied, reproduced or translated to another language without the prior written consent of the Laboratory of Building Physics.